COMPANY WITH
QUALITY SYSTEM
CERTIFIED BY DNV GL
= ISO 9001 =

Use and Maintenance Manual

Enclosures series
QL – QLP – DS
For environments with Potentially Explosive Atmospheres Directive (2014/34/UE)

ilinox S.r.l. Strada Prov Asolana 4/6 – 43056 San Polo di Torrile (PR) - Phone: +39 0521 813629 *fax*: +39 0521 813570 *e-mail*: info@ilinox.com - www.ilinox.com

1. FIELD OF APPLICATION

This Manual applies to protective enclosures, made of stainless steel,

in the series QL and QLP, designed to work in areas (1 - 21 - 2 - 22) and

in the series DS, designed to work in areas (20 - 1 - 21 - 2 - 22)
in the presence of gas and/or powders, in compliance with Directive 201-34-UE
The enclosures have NO see-through sections.
The series QL, QLP, have the following maximum sizes: Width (W) x Height (H) x Depth (D) (800 x 1.600 x 400)
The series DS, have the following maximum sizes: Width (W) x Height (H) x Depth (D) (750 x 600 x 400)

The enclosures are merely components, i.e. a part of electric systems NOT intended to be used on its own and which requires additional consideration when it is included in an electric construction or in a system for use in explosive atmospheres.

2. TERMS AND DEFINITIONS

Group I
Electric construction for gassy mines

Group II
Electric construction for places with potentially explosive atmosphere, other than the gassy mines.

CATEGORY
Classification according to the protection degree required.

ZONE
Dangerous place where hazardous explosive atmosphere can be present. The areas differ depending on the frequency and duration of the presence of the hazardous explosive atmosphere.

ZONE 1
Place where the explosive atmosphere, formed by a mixture of air and flammable materials in the form of gas, vapour or mist might be present from time

ZONE 2
Place where the explosive atmosphere, formed by a mixture of air and flammable materials in the form of gas, vapour or mist may be present during routine working but which, when present, lasts just a while.

ZONE 20
Place where an explosive atmosphere is present in the form of a cloud of combustible powders in the air, either continuously, or for extended times, or frequently.

ZONE 21
Place where an explosive atmosphere, in the form of a cloud of airborne combustible powders can be present from time to time during routine working.

ZONE 22
Place where an explosive atmosphere is not likely to take place, in the form of a cloud of combustible powders in the air, during regular operation and, if it forms, it lasts only for a short time.

A link exists between zone and Category, as follows:

Zone 20 Category 1D	Zone 21 Category 2D	Zone 22 Category 3D
	Zone 1 Category 2G	Zone 2 Category 3G

MAXIMUM SURFACE TEMPERATURE
Maximum temperature attained in operation, under the most unfavourable conditions (yet within the specified allowances), by every part or surface of an electric construction, which might cause the ignition of the surrounding explosive atmosphere..
(Determined with room temperatures ranging between -20 °C and +40 °C)

IGNITION TIME OF A COMBUSTIBLE GAS
The lowest temperature of a heated surface, determined in the specified test conditions, at which a combustible substance in the form of a mixture of gas or vapour with the air ignites.

MINIMUM IGNITION TEMPERATURE of a CLOUD or a LAYER of POWDERS
The lowest temperature of a hot surface, at which the ignition of the powders with the air or in layer of powders occurs at the specified test conditions.

3. IDENTIFICATION

The **STANDARD** enclosures are identified in the catalogue by codes, having the following meaning:

item	Type	Sizes	Gasket material	Enclosure material	Notes
QL _ _ /304-EX	Type of enclosure QL or QLP	_ _ Identifies the container	Foamed polyurethane	Inox 304	EX Fit for zones atex 1 – 2 21 - 22
QL _ _ S/304-EX			Foamed silicone	Inox 304	
QL _ _ /316-EX			Foamed polyurethane	Inox 316L	
QL _ _ S/316-EX			Foamed silicone	Inox 316L	
QLP _ _ -EX			Foamed polyurethane	Inox 304	
QLP _ _ S-EX			Foamed silicone	Inox 304	

DS _ _ /304-EX	Type of enclosure DS	_ _ Identifies the container	Foamed polyurethane	Inox 304	EX Fit for zones atex 1 – 2 20 – 21 - 22
DS _ _ S/304-EX			Foamed silicone	Inox 304	
DS _ _ /316-EX			Foamed polyurethane	Inox 316L	
DS _ _ S/316-EX			Foamed silicone	Inox 316L	

The SPECIAL enclosures are identified by codes, having the following meaning:

Item	Type	Sizes	Numbering	Notes
QL._ _ _ _ _ _ _ _ -EX	Type of enclosure QL or QLP	Special sizes not identified by the code	_ _ _ _ _ _ _ _ identifies the number of the reference assembly drawing	EX Fit for zones atex 1 – 2 21 - 22
QLP._ _ _ _ _ _ _ _ -EX				

QL._ _ _ _ _ _ _ _ -EX	Type of enclosure DS	Special sizes not identified by the code	_ _ _ _ _ _ _ _ identifies the number of the reference assembly drawing	EX Fit for zones atex 1 – 2 20 – 21 - 22

Further information including the gasket material and the enclosure material can be obtained directly from the drawing or from p/o confirmation.

4. MARKING

Label for QL – QLP



Label for x DS



(item) : ID item of enclosure
IP : Protection degree of enclosures UNI EN 60529/A1
6x : Fully protected against powder
x6 : Protected against penetration of powerful water sprays
II : Group II electric construction for places featuring potentially explosive atmosphere, other than gassy mines
1 or 2 : Category according to the protection degree required
G : Gas: suiting potentially explosive atmospheres with the presence of gas.
D : Dust: suiting potentially explosive atmospheres with the presence of combustible powders
U : Indicates that this is a component, **it is not designed to be used on its own, additional consideration is required when it is incorporated in an electric construction**.

EUM1 11 ATEX 0598 U : Number of EC type examination certificate issue by EUROFINS - MODULO UNO S.p.A.

NB: Notified Body that has the supervision of the production: (0477) EUROFINS TECH S.r.l.

Lot : X XXXX ID of the lot and (YYYY) manufacture year

The protection degree is assured by the enclosure when NOT drilled; when drillings are present, the protection degree can be preserved only by <u>properly</u> installing instrument featuring same or higher protection degree.

5. TRANSPORTATION

The enclosures are delivered packed in cartons or pluriball.
Transportation must take place without tampering the package, avoiding knocking the enclosure.

6. STORAGE

The enclosures must be stored in places clean, free from corrosive atmosphere, inside their original packages.
Storage conditions: temperatures higher than 0 °C, l ower than 60 °C and air humidity LOWER than 80%.

7. COMMISSIONING

Environmental atmospheric conditions as per regulations:
Temperatures ranging from -20 °C to +40 °C;
Atmospheric pressure ranging from 80 kPa (0,8 Bar) to 110 kPa (1,1 Bar);
Air featuring regular oxygen content, usually 21% v/v.

8. USE

The enclosures are made of EN 1.4301 (AISI 304) or EN 1.4404 (AISI 316L) s/s (Identified by marking on the door).
On demand they could be realized in s/s EN 1.4307 or 1.4306 (AISI 304L) or EN 1.4401 or 1.4436 (AISI 316) or EN 1.4432 or 1.4435 (AISI 316L) or EN 1.4571 (316Ti)
The gasket are made from bi-component polyurethane or bi-component silicone.

The fitter is bound to make sure the materials used in the manufacture are compatible with the installation zone. (see also table A)

The enclosures are supplied protected by adhesive film, which must be removed prior to start to operation **(IMPORTANT see Chapter 10)**.

The enclosure can be used with the following Maximum Temperatures of the outside surface:
-20 °C to +60 °C with gasket of bi-component foamed polyurethane
-40 °C to +180 °C with gasket of bi-component foame d silicone

Humidity NOT exceeding 80%
Enclosure tightness degree (without drillings): IP66

The enclosures are fit for use with the following protection systems:

ELECTRIC PROTECTION SYSTEM for GAS				
Protection method		Category 1 Zone 0	Category 2 Zone 1	Category 3 Zone 2
p	Inner over-pressure	NO	YES	YES
e	Increased safety	NO	YES	YES
ib	Intrinsic safety	NO	YES	YES
n	Simplified	NO	YES	YES

ELECTRIC PROTECTION SYSTEM for POWDERS				
Protection method		Category 1 Zone 20	Category 2 Zone 21	Category 3 Zone 22
tb (Protection by enclosures)	IP6X	YES (only for DS series)	YES	YES
	IP5X	========	========	YES (Only with **NON** Con-conductive powders)

The checks and tests carried out relieve the manufacturer of the final equipment from the tests and inspections concerning the mechanical sturdiness of the appliance, the IP protection degree, the thermal strength of the seal (within the limits of the information provided in the Manual) and the maximum overpressure (4 KPa for the junction boxes series DS, 2 KPa for the others); all the other tests/inspections provided for by the rules applicable to the final equipment are at the charge of the end manufacturer.

9. ASSEMBLING AND DISASSEMBLING

The enclosures can be drilled to allow the installation of instruments or the entry of cables.
Drillings can be done in compliance with the minimum parameters summarized in figures 1, 2, 3, 4 and 5 below:

DRILLINGS for Series QL – QLP (Fig. 1)



A (mm)	40	Minimum
B (mm)	80	Minimum
C (mm)	20	Minimum

THE INSTRUMENTS or ACCESSORIES TO BE INSTALLED, MUST HAVE SUCCESSFULLY OVERCOME THE MECHANICAL IMPACT TEST EQUAL TO 7 J at least.

FOR ANY DOUBTS, DON'T HESITATE TO CONTACT ILINOX TECHNICAL DEPARTMENT.

DRILLINGS for Serie QL – QLP MANOMETER-HOLDER (Fig. 2)



A (mm)	40	Minimo
B (mm)	80	Minimo
C (mm)	20	Minimo

THE INSTRUMENTS or ACCESSORIES TO BE INSTALLED, MUST HAVE SUCCESSFULLY OVERCOME THE MECHANICAL IMPACT TEST EQUAL TO 7 J at least.
FOR ANY DOUBTS, DON'T HESITATE TO CONTACT ILINOX TECHNICAL DEPARTMENT.

DRILLINGS for Series DS (Fig. 3)



X (mm)	30	Minimum
Y (mm)	20	Minimum

The INSTRUMENTS or ACCESSORIES TO BE INSTALLED MUST HAVE SUCCESSFULLY OVERCOME THE MECHANICAL IMPACT TEST EQUAL TO 7 J AT LEAST.

FOR ANY DOUBTS DO NOT HESITATE TO CONTACT ILINOX TECHNICAL DEPARTMENT.

Fairlead plates for QL - QLP (Fig. 4)



A (mm)	35	Minimum
C (mm)	20	Minimum

The INSTRUMENTS or ACCESSORIES TO BE INSTALLED MUST HAVE SUCCESSFULLY OVERCOME THE MECHANICAL IMPACT TEST EQUAL TO 7 J AT LEAST.
FOR ANY DOUBTS DO NOT HESITATE TO CONTACT ILINOX TECHNICAL DEPARTMENT.

Fairlead plates for DS (Fig. 5)



A (mm)	25	Minimum
C (mm)	20	Minimum

The INSTRUMENTS or ACCESSORIES TO BE INSTALLED MUST HAVE SUCCESSFULLY OVERCOME THE MECHANICAL IMPACT TEST EQUAL TO 7 J AT LEAST.
FOR ANY DOUBTS DO NOT HESITATE TO CONTACT ILINOX TECHNICAL DEPARTMENT.

The enclosures can be secured to the wall or to a bearing frame, in compliance with the instructions (see Figure 6 and 7).
Every source of vibration can be harmful therefore, in the presence of this phenomenon, suitable protections such as VIBRATION DAMPERS must be set up.

The enclosures are arranged for earthing on all the parts NOT welded to each other (doors, envelopes, inner plates), there is a predisposition of external earthing. The dimension of connecting element for earthing is M6x15.
The earthing point being clearly marked with the pictorial

The parts that can be disassembled and which may hinder the operating integrity of the enclosure are the doors or the covers.
Doors of the series QL and QLP, keep to the instructions (see Figure 8).
Covers of the series DS, are only screwed by Allen wrench, so NO special instruction is required; the only requirement i sto NOT exceed the tightening torque shown below.

The screws and/or nuts must NOT be tightened to torque values exceeding those indicated below

Thread	M4	M5	M6	M8	M10	M12
Nm	*2,0*	*3,2*	*5,0*	*10*	*16*	*25*

10. MAINTENANCE AND REPAIRS

For any maintenance operations for which the door or the cover of the enclosure must be opened, make sure the explosive atmosphere does not get in touch with inner hot surfaces or live parts; to this effect, place on the enclosure this WARNING directions:
AFTER SWITCHING OFF, WAIT _ _ _ _ _ MINUTES BEFORE OPENING
DO NOT OPEN IN THE PRESENCE OF EXPLOSIVE ATMOSPHERE
DO NOT OPEN WHILE ENERGIZED
Evaluation of suitability of these information lie within competence of manufacturer of finished instrument.

In order to prevent the building-up of dangerous layers of explosive powders, the enclosure must be cleaned to avoid the build-up of a layer thicker than 5 mm.

Every time you open the enclosure, check the integrity of the gaskets and replace them IMMEDIATELY, if the need be.

If NO opening is foreseen for doors or panels, check the integrity of the seal with such a frequency as to comply with the laws in force in the place of installation of the enclosures (if any), otherwise with intervals NOT exceeding 2 years.

Check the surface of the enclosure at least once a year, No evidence of corrosion or formation of rust particles must be observed.

Any alteration and/or repair to the enclosure (except for the drillings according to chapter 9) unless authorized by ILINOX s.r.l., will nullify the conformity of the component and cancel all and every responsibility.

Repairs and/or modifications involving the use of tools that may cause ignition of explosion:
MUST be done in SAFE areas (free from gas and/or inflammable gases).
MUST be done after reclaiming the container to avoid gas stagnation.
MUST be done after removal of the potentially explosive powders.

Repairs and/or modifications must be done by Workshops having the specific equipment required, by personnel having technical know-how and in compliance with the safety rules in force.
They must be documented and kept in the technical documents of the equipment.

The use of NON original spare parts, if any, nullifies the component conformity and makes all and the responsibility of ILINOX s.r.l. null and void.

11. INSTALLATION

S/s features good strength to corrosion, provided they can passivate thus forming a protection layer against corrosion agents. Once the protecting film has been REMOVED, the enclosure must be left exposed to the air in a clean environment (the atmosphere shall not contain pollutants like: iron oxide, salts, salinity, chlorides, organic vapours …..)

Check that the material HAS NOT been attacked by "rust" particles from machining with UNFIT tools; if this occurs, they must be removed by suitable pickling agents as they are a source of corrosion as well as of possible striking due to violent shock or rubbing.

The enclosure can be installed in zones where explosive atmospheres are present due to gases or powders.
The areas of competence are: 20 – 1 – 21 – 2 - 22 for the series DS only
1 – 21 – 2 - 22 for the series QL - QLP.

The fitter must know exactly the zone where the enclosure is going to be installed, such zones being identified according to rule CEI EN 60079-10-1 for the presence of gas and/or CEI EN 60079-10-2 for the presence of combustible powders.

The fitter is also committed to check that the materials used in the manufacture are compatible with the atmosphere of the installation zone.

UNFIT for explosive powders NOT requiring oxygen for combustion.
UNFIT for pyrophoric substances.
UNFIT for underground mines.
UNFIT for installation on the surface of mines made hazardous by the presence of grisou and/or combustible powders.
UNFIT in environment containing chlorides.

12. SAFETY DATA

When using sealants, these must stand temperatures 20°higher than the Maximum Surface Temperature and at least 10°lower than the minimum operating temperature.

GAS
Zone of possible installation are : 1 - 2.
Category of the system 2 , 3.
Maximum Surface Temperature **<=** 80% Minimum temperature of gas ignition (for constructions Category 2).
Maximum Surface temperature **<=** Minimum temperature of gas ignition (for construction Category 3).

POWDERS
Zones of possible installation are:
20 – 21 – 22 for the series DS only; 21 - 22 for the series QL - QLP.
Category of the system: 1 – 2 – 3 for the series DS only; 2 - 3 for the series QL - QLP.
Maximum Surface Temperature **<=** 2/3 minimum temperature of powder ignition with a minimum gap of 75 K.

13. APPLICABLE REGULATIONS

EN 60079-0:2012 A11:2013	EN 60079-2:2007	EN 60079-7:2007	EN 60079-11:2012	EN 60079-15:2010
	EN 60079-31:2014	EN 13463-1:2009	EN 1127-1:2011	

14. PROTECTION DEGREE

The enclosures are delivered with protection degree tested on laboratory sample: IP66
If drillings are made on the enclosure, they cause the LOSS of the protection degree UNLESS they are properly closed by accessories or instruments featuring the same protection degree and properly installed.
If accessories or instruments featuring lower protection degree are set-up, the enclosure takes up the lowest protection degree installed.

15. STRUCTURE PERFORMACE

The enclosures are delivered after mechanical crash test equal to 7 J, provided the minimum and maximum drilling values indicated in Chapt. 8 are complied with.
If such values are NOT respected:

- The test report is to be considered void and MUST be performed again on the final electric construction, at fitter's charge unless a different opinion is given by the Notified Body chosen by him.
- It makes the conformity of the component void an null and any responsibility by ILINOX s.r.l. will cease.

Schedule – Corrosion strength

These schedules are a summary of the most reliable laboratory data currently available on the corrosion strength of the materials being considered

When using these schedules, it will however be advisable to keep into consideration that the results are from laboratory tests and are therefore to be considered as a recommendation and NOT as an absolute guarantee.

		AISI304	AISI316L	Bi-component polyurethane	Bi-component silicone
Butyl acetate	+21°	1	1	C1	B1
Ethyl acetate	Ta	2	2	D1	B1
Methyl acetate	Ta	1	1	D1	B1
Acetylene	+20°	1	1	A1	A1
Vinegar	+20°	1	1	B1	==
Acetone	E	1	1	E1	B1
Benzoic acid benzoico	+20°	2	2	A1	A1
Boric acid 5%	C	2	2	A1	A1
Citric acid 5%	+20°	1	1	A1	A1
Hydrochloric acid		4	4	A1	A1
Chromic acid 5%	+20°	2	-	E1	B1
Formic acid 5%	+20°	2	2	E1	C1
Nitric acid 5%	+20°	1	1	E1	A1
Oleic acid	+20°	2	2	A1	A1
Sea water	+20°	2	2	A1	A1
Soft water	Ta	1	1	A1	A1
Ethylic acid	+20°	2	2	C1	A1
Carbon dioxidecarbonica	Ta	1	1	A1	A1
Nitrogen	Ta	1	1	A1	A1
Gasoline	+20°	1	1	C1	B1
Ammonium carbonate	Ta	2	2	A1	A1
Barium carbonate	Ta	2	2	A1	A1
Calcium carbonate	+20°	2	2	A1	A1
Cyclohexane	Ta	1	1	D1	C1
Chlorobenzene	+20°	1	1	D1	D1

		AISI304	AISI316L	Bi-component polyurethane	Bi-composant silicone
Chloroform	+20°	1	1	D1	E1
Barium chloride 5%	+20°	2	2	A1	A1
Calcium chloride	+20°	3	2	A1	A1
Methylene	Ta	1	1	E1	C1
Eptane	Ta	1	1	B1	C1
Hexane	Ta	2	2	B1	C1
Ethylic ether	+20 °	1	1	C1	B1
Natural gas	Ta	1	1	A1	A1
Glycerine	+20°	1	1	A1	A1
Ethylic glycol	+20°	1	1	B1	A1
Hydrogen	Ta	1	1	A1	A1
Barium hydroxide	Ta	2	2	A1	A1
Ink	Ta	1	1	A1	A1
Latex	+20°	1	1	A1	==
Methane	Ta	2	2	A1	A1
Neon	+20°	2	2	A1	A1
Castor oil	Ta	1	1	A1	A1
Mineral oil	Ta	1	1	A1	A1
Ozone	Ta	1	1	B1	B1
Paraffin wax	Ta	1	1	A1	A1
Barium sulphate	+20°	2	2	A1	A1
Soapy solutions	Ta	1	1	A1	A1
Carbon tetrachloride	Ta	2	2	D1	E1
Urea	Ta	2	2	A1	A1
Petrolatum	Ta	2	2	A1	A1

Key

STAKINLESS STEEL			GASKET	
1	EXCELLENT	Materials that do not experience substantial dimensional changes. Corrosion rate less than at penetration of 0,13 mm/year	A1	Excellent
2	Good	Materials that are not attacked, but that are generally required where a certain degree of tolerance can be accepted. Corrosion rate 0,1 ÷ 0,5 mm/year	B1	Good
3	Poor strength	Materials that are not usually considered suitable for most of the applications in chemical plants. Corrosion rate 0,5 ÷ 1,26 mm/year	C1	Acceptable
4	Not recommended	Materials whose corrosion rate is too high to be taken into consideration Corrosion rate higher than 1,26 mm/year	D1	Poor
-	No information available		E1	Destroyed

E = Boiling C = Hot Ta = Room temperature

WALL-MOUNT RESTS for QL – QLP (Fig. 6)







WALL MOUNT RESTS for DS (Fig. 7)



















DOOR ASSEMBLING / DISASSEMBLING QL-QLP (Fig. 8)



ilinox

COMPANY WITH QUALITY SYSTEM CERTIFIED BY DNV GL = ISO 9001 =

Attestato di conformità componenti
Conformity declaration

ILINOX S.r.l.

Strada Provinciale Asolana n°4/6 – 43056 S. Polo di Torrile (PR) Italy

dichiara sotto la propria responsabilità che gli armadietti della serie:
declares on its own responsibility, that the cabinet:

QL ..... EX

sono conformi alla Direttiva Comunitarie:
are in compliance with the *European Directive:*

2014/34/UE(atex)

sono considerati "componenti" ai sensi dell'art. 1, par. 3(c) della direttiva
considered as components, according to art. par. 3(c)

Norme armonizzate applicate:
Applied harmonized standards :

EN 60079-0 :2012 A11:2013 / EN 60079-2:2007 / EN 60079-7:2007 / EN 60079-11:2012
EN 60079-15:2010 / EN 60079-31:2014 / EN 13463-1:2009 / EN 1127-1:2011

Marcatura applicata :
Marking :

II 2 GD U

I prodotti ed il fascicolo tecnico sono stati oggetto di rapporto di approvazione N°.
Products and technical manual has been tested and approved in compliance with a report No.

M1.11.REL.01/43712 + M1.13.REL.01/50083

dall'organismo notificato EUROFINS – MODULO UNO S.p.A.
Con emissione del certificato di esame CE del tipo N°.
by the notified body EUROFINS – MODULO UNO S.p.A.
EC- type examination certificate No.

EUM1 11 ATEX 0598 U + SUPPLEMENT No.2

e sono sottoposti a procedure di controllo di GARANZIA QUALITA' (allegato VII direttiva -2014/34/UE) con sorveglianza dell'organismo notificato:
and they are submitted to procedure of QUALITY ASSURANCE (annex VII direttive -2014/34/EU) with surveillance by Notified Body:

EUROFINS PRODUCT TESTING ITALY S.r.l. (0477)

San Polo di Torrile: 10.08.2016

ilinox
Allodi Claudio
Managing Director

ilinox S.r.l. Strada Prov. Asolana 4/6 - 4356 San Polo di Torrile (PR) - tel.: +39 0521 813629 fax: +39 0521 813570 e-mail : info@ilinox.com - www.ilinox.com

ilinox

COMPANY WITH QUALITY SYSTEM CERTIFIED BY DNV GL = ISO 9001 =

Attestato di conformità componenti
Conformity declaration

ILINOX S.r.l.

Strada Provinciale Asolana n°4/6 – 43056 S. Polo di Torrile (PR) Italy

dichiara sotto la propria responsabilità che le scatole di derivazione della serie:
declares on its own responsibility, that the junction boxes:

DS ..... EX

sono conformi alla Direttiva Comunitarie:
are in compliance with the *European Directive:*

2014/34/UE(atex)

sono considerati "componenti" ai sensi dell'art. 1, par. 3(c) della direttiva
considered as components, according to art. par. 3(c)

Norme armonizzate applicate:
Applied harmonized standards :

EN 60079-0:2012 A11:2013 / EN 60079-2:2007 / EN 60079-7:2007 / EN 60079-11:2012
EN 60079-15:2010 / EN 60079-31:2014 / EN 13463-1:2009 / EN 1127-1:2011

Marcatura applicata :
Marking :

II 1D 2G U

I prodotti ed il fascicolo tecnico sono stati oggetto di rapporto di approvazione N°.
Products and technical manual has been tested and approved in compliance with a report No.

M1.11.REL.01/43712 + M1.12.REL.01/49142 + M1.13.REL.01/50083

dall'organismo notificato EUROFINS – MODULO UNO S.p.A.
Con emissione del certificato di esame CE del tipo N°.
by the notified body EUROFINS – MODULO UNO S.p.A.
EC- type examination certificate No.

EUM1 11 ATEX 0598 U + SUPPLEMENT No.1 + SUPPLEMENT No.2

e sono sottoposti a procedure di controllo di GARANZIA QUALITA' (allegato VII direttiva – 2014/34/UE) con sorveglianza dell'organismo notificato:
and they are submitted to procedure of QUALITY ASSURANCE (annex VII direttive – 2014/34/EU) with surveillance by Notified Body:

EUROFINS PRODUCT TESTING ITALY S.r.l. (0477)

San Polo di Torrile: 10.08.2016

ilinox
Allodi Claudio
Managing Director

ilinox S.r.l. Strada Prov. Asolana 4/6 - 4356 San Polo di Torrile (PR) - tel.: +39 0521 813629 fax: +39 0521 813570 e-mail : info@ilinox.com - www.ilinox.com